

General Information: CITY COLLEGE COVENTRY			
Plant Name: PUHP100YH8		Reference No: CU1N	
Location of plant: External Ground			
Cooling loads served: Maintenance		Refrigerant Quantity (kg): 4.4	
Refrigerant Type: R410A	GWP: 2088	CO <sub>2</sub> Equivalent: 9.187	
Plant Manufacturer: Mitsubishi		Year of installation:	
Refrigerant Additions			
Date	Engineer	Amount Added Kg	Reason for addition
Refrigerant Removals			
Date	Engineer	Amount Removed KG	Reason for removal. What was done with recovered refrigerant
Leak Tests			
Date	Engineer	Test Result	Follow up actions required
28.10.11	W.Watson	Pass	Next Leak Test Required 28.10.12
02.11.12	W.Watson	Pass	Next Leak Test Required 02.11.13
01.11.13	W.Watson	Pass	Next Leak Test Required 01.11.14
31.10.14	W.Watson	Pass	Next Leak Test Required 31.10.15
29.10.15	W.Watson	Pass	Next Leak Test Required 29.10.16
Follow-up Actions			
Date	Engineer	Related to test on	Actions Taken
Testing of Automatic Leak Detection System (if fitted)			
Date	Engineer	Test Result	Comments