

General Information: CITY COLLEGE COVENTRY			
Plant Name PUHZRP6oVHA2		Reference No: C U17S	
Location of plant: Roof			
Cooling loads served: Comms Cupboard		Refrigerant Quantity (kg): 3.5	
Refrigerant Type: R410A	GWP: 2088	CO2 Equivalent: 7.308	
Plant Manufacturer: Mitsubishi		Year of installation:	
Refrigerant Additions			
Date	Engineer	Amount Added Kg	Reason for addition
Refrigerant Removals			
Date	Engineer	Amount Removed KG	Reason for removal. What was done with recovered refrigerant
Leak Tests			
Date	Engineer	Test Result	Follow up actions required
28.10.11	W.Watson	Pass	Next Leak Test Required 28.10.12
02.11.12	W.Watson	Pass	Next Leak Test Required 02.11.13
01.11.13	W.Watson	Pass	Next Leak Test Required 01.11.14
31.10.14	W.Watson	Pass	Next Leak Test Required 31.10.15
29.10.15	W.Watson	Pass	Next Leak Test Required 29.10.16
Follow-up Actions			
Date	Engineer	Related to test on	Actions Taken
28.10.16	T.Lee	Pass	Next Leak test due 28.04.17
26.04.17	W.Watson	Pass	Next Leak test due 26.10.17
Testing of Automatic Leak Detection System (if fitted)			
Date	Engineer	Test Result	Comments

General Information: CITY COLLEGE COVENTRY			
Plant Name PUHZRP6oVHA2		Reference No: C U17S	
Location of plant: Roof			
Cooling loads served: Comms Cupboard		Refrigerant Quantity (kg): 3.5	
Refrigerant Type: R410A	GWP: 2088	CO2 Equivalent: 7.308	
Plant Manufacturer: Mitsubishi		Year of installation:	
Refrigerant Additions			
Date	Engineer	Amount Added Kg	Reason for addition
Refrigerant Removals			
Date	Engineer	Amount Removed KG	Reason for removal. What was done with recovered refrigerant
Leak Tests			
Date	Engineer	Test Result	Follow up actions required
28.10.16	T.Lee	Pass	Next Leak test due 28.04.17
26.04.17	W.Watson	Pass	Next Leak test due 26.10.17
06.11.17	W.Watson	Pass	Next leak test due 06.05.18
17.04.19	W.Watson	Pass	Next leak test due 17.10.19
24.10.19	W.Watson	Pass	Next leak test due 24.04.20
26.10.20	W.Watson	Pass	Next leak test due 26.04.21
Follow-up Actions			
Date	Engineer	Related to test on	Actions Taken
Testing of Automatic Leak Detection System (if fitted)			
Date	Engineer	Test Result	Comments