



General Information: CITY COLLEGE COVENTRY								
Plant Name:	PUHP100YH8		Reference No: CU4N					
Location of plant: Roof								
Cooling loads	served: Data Room		Refrigerant Quantity (kg): 4.4					
Refrigerant Type: R410A GWP: 2088			CO2 Equivalent: 9.187					
Plant Manufacturer: Mitsubishi			Year of installation:					
Refrigerant Additions								
Date	Engineer	Amount Added Kg		Reason for addition				
Refrigerant Removals								
Date	Engineer	Amount Removed KG		Reason for removal. What was done with recovered refrigerant				
Leak Tests								
Date	Engineer	Test Result		Follow up actions required				
28.10.11	W.Watson	Pass		Next Leak Test Required 28.10.12				
02.11.12	W.Watson	Pass		Next Leak Test Required 02.11.13				
01.11.13	W.Watson Pass			Next Leak Test Required 01.11.14				
31.10.14	W.Watson	Pass		Next Leak Test Required 31.10.15				
29.10.15	W.Watson	Pass		Next Leak Test Required 29.10.16				
Follow-up Actions								
Date	Engineer	Related to test on		Actions Taken				
28.10.16	T.Lee	Pass		Next Leak test due 28.04.17				
26.04.17	W.Watson	Pass		Next Leak test due 26.10.17				
Testing of Automatic Leak Detection System (if fitted)								
Date	Engineer	Test Result		Comments				





General Information: CITY COLLEGE COVENTRY								
Plant Name: PUHP100YH8				Reference No: CU4N				
Location of plant: Roof								
Cooling loads	served: Data Room		Refrigerant Quantity (kg): 4.4					
Refrigerant Type: R410A GWP: 2088			CO2 Equivalent: 9.187					
Plant Manufacturer: Mitsubishi			Year of installation:					
Refrigerant Additions								
Date	Engineer	Amount Added Kg		Reason for addition				
Refrigerant Removals								
Date	Engineer	Amount Removed KG		Reason for removal. What was done with				
				recovered refrigerant				
Leak Tests								
Date	Engineer	Test Result		Fallow up actions required				
28.10.16	Engineer T.Lee	Pass		Follow up actions required  Next Leak test due 28.04.17				
	W.Watson	Pass		Next Leak test due 26.04.1/ Next Leak test due 26.10.17				
26.04.17	W.Watson	Pass		·				
06.11.17	W.Watsom	Pass		Next leak test due 06.05.18  Next leak test due 17.10.19				
17.04.19								
24.10.19	W.Watson W.Watson	Pass		Next leak test due 24.04.20				
26.10.20		Pass		Next leak test due 26.04.21				
Follow-up Ac		Related to test on		Actions Taken				
Date	Engineer	Related to test on		Actions raken				
Tanking	damaka Lask Buta di	Contain (if fitted)						
Testing of Automatic Leak Detection System (if fitted)								
Date	Engineer	Test Result		Comments				