

Display energy certificate (DEC)



HM Government

SOUTH BUILDING
Coventry College
50 Swanswell Street
COVENTRY
CV1 5DG

Operational rating

D

Certificate number: 9922-0276-3159-2754-0694

Valid until: 30 January 2023

Total useful floor area: 11500 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C		
76-100	D	76 D	
			100 ..
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
January 2022	76 D
February 2021	71 C
February 2020	71 C

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
January 2022	651	166	0
February 2021	558	175	0
February 2020	604	143	0

Assessment details

Assessor's name: Adrian Newton

Employer/Trading name: ESOS Energy Ltd

Employer/Trading address: 2nd Floor Tower House, Fairfax Street, Bristol, BS1 3BN

Assessor's declaration: Contractor to the occupier for EPBD services only.

Accreditation scheme: CIBSE Certification Limited

Issue date: 6 January 2022

Nominated date: 31 January 2022

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	102.89	74.27
Typical energy use (kWh/m ² /year)	80	251.70
Energy from renewables	0%	0%

