

Display energy certificate (DEC)



HM Government

NORTH BUILDING
Coventry College
50 Swanswell Street
COVENTRY
CV1 5DG

Operational rating

C

Certificate number: 9925-7242-9149-9732-1554

Valid until: 30 January 2023

Total useful floor area: 13480 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A	68 C	100 ..
26-50	B		
51-75	C		
76-100	D		
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	82.53	92.46
Typical energy use (kWh/m ² /year)	80	251.70
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
January 2022	68 C
February 2020	66 C
February 2019	79 D

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
January 2022	612	242	0
February 2020	602	214	0
February 2019	661	326	0

Assessment details

Assessor's name	Adrian Newton
Employer/Trading name	ESOS Energy Ltd
Employer/Trading address	2nd Floor Tower House, Fairfax Street, Bristol, BS1 3BN
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	6 January 2022
Nominated date	31 January 2022

