

ENVIROCHEM

Analytical Laboratories Ltd

12 The Gardens, Broadcut, Fareham Hampshire. PO16 8SS

Fibre Counting Report

Tel: (01329) 287777 Fax: (01329) 287755

CLIENT:

SITE ADDRESS: HMS Deadalus, Broom Way, Lee-on-Solent, PO13 9YA

Homes and Communities Agency, 2 Rivergate, Temple Quay, Bristol, BS1

Our Ref: J113330FC4

Your Ref:

SAMPLING PROTOCOL: Background

SAMPLED BY:

DATE OF SAMPLING: 02/01/17

ANALYSED BY (if different):

DATE OF ANALYSIS (# J:# -----

| | | | DAIL OF SAMELING: 03/01/ | | | DATE OF ANALYSIS (if different): | | | | | | | | |
|---------------|------|------|--|---------|----------|----------------------------------|-----------------------------------|------------------------|-------------------------|--------------|---------------|--------------------------|---------------------------------|--|
| Filter No. | Pump | Head | Location | Time on | Time off | Flow (start) | low (litres/1 Flow (finish) | nin) Flow (used) | Volume (V) litres | Grats (n) | Fibres (N) | Calculation fibres/ml | Reported result fibres/ml | |
| FC1 | FU4 | RC7 | Within ground floor bathroom | 10:04 | 11:04 | 8.0 | 8.0 | 8.0 | 480 | 200 | 1 | 0.002 | <0.01 | |
| FC2 | 24 | RC22 | Ground floor corridor adj to back door | 10:05 | 11:05 | 8.0 | 8.0 | 8.0 | 480 | 200 | 1/2 | 0.001 | <0.01 | |
| FC3 | FU4 | RC7 | Ground floor corridor adj to back door | 12:07 | 13:07 | 8.0 | 8.0 | 8.0 | 480 | 200 | 2 | 0.001 | <0.01 | |
| FC4 | 24 | RC22 | Within ground floor bathroom | 13:15 | 14:15 | 8.0 | 8.0 | 8.0 | 480 | 200 | 2 | 0.001 | <0.01 | |
| | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | |

- 1. Unless otherwise stated, the detection limit is 0.01 fibres/ml.
- Comments, observations and opinions are outside the scope of UKAS accreditation.
- For clearance sampling, this report must be read in conjunction with the certificate of reoccupation.

- 2. Samples collected by the client are evaluated using information provided by the client.
- Fibres were counted on membrane filter(s) in accordance with the HSE Guidance Note HSG 248.

Equipment Numbers:

Microscope: 10 Stage Micrometer: 3

Tally Counter: 8/US

Barometer:

Flow Meter:

Thermometer: BTC40

BTC40

FM30

Temperature (°C): 5 Pressure (mb):

Environment:

Correction Factor (F): ----

Diam. of dust deposit (D) (mm): 22.5 Test Slide (5 bands): Yes/No

W/B Grat diameter (µm): 100

Blank Filter

Head: Graticules: ----

Fibres:

Place of Analysis:

Lab HY14 DFC

On Site Mob Lab

Comments

Background air monitoring during the removal of artex ceiling in building 14. Air test satisfactory.

SIGNATURE:

(on behalf of Envirochem by an authorised signatory)

ENVIROCHEM/FORMS/WORKSHEETS/02/ISSUE07/NOV06

PRINT NAME: