

Fire Officer Consultation Schedule | Building Control

Project Reference: PG000041176

Description of Work & Building Control Comments

SITE NOTES:Telephone: 01730 234207 - building.control@easthants.gov.uk Section 11 Hampshire Act 1983OTHER: CAR PARKING. Section 12 Hampshire Act 1983 ACCESS FOR THE FIRE BRIGADE. SITE DESCRIPTION:Construction of 37 detached, 50 semi detached and 17 terraced dwellings and 6 apartments

The means of escape from the upper floors has been designed as a small single stair building Complying with the requirements within paragraph 2.21 Approved Document B Vol 2.I have requested that the AOV is operated via the fire alarm being activated. Further information has also been requested regarding the Exit signage and emergency lighting. This information will be forwarded when received.

All plans are on enclosed disc

Location

Off Brislands Lane, Four Marks, Hampshire, GU34 5AD

Project Directory

Approved Inspector	Fire Authority
Premier Guarantee Surveyors, 2 Shore Lines Building, Shore Road, Birkenhead, Wirral, CH41 1AU	Hampshire Fire & Rescue Service Headquarters, Leigh Road, Eastleigh, Hampshire, SO50 9SJ
Applicant Sovereign Housing Association 17-24 Bartholomew Street, Newbury, RG14 5LL	Agent / Architect

Drawing Title and Reference

Persimmions+Brinslands+Lane+Four+Marks_237436.doc