

## Andrew Smith

---

**From:** Andrew Smith  
**Sent:** 06 April 2011 13:38  
**To:** 'Michael Dawson'  
**Subject:** RE: Glenridding Public Hall

Michael

I have had a quick look at the plans, and your application will need to include the following:

- Form
- Site location plan
- Existing and proposed floor plans, roof plans, elevations, large scale sectional detail showing fitting of solar panels, large scale vertical and horizontal typical sections of the proposed windows
- Design & Access Statement
- Bat survey (because of the works to the roof)
- Short method statement re: working methods to prevent pollution of beck (e.g. all materials to be stored and all concrete mixed on car park, prevent run off to beck etc etc)
- Fee £85

Given the setting and position of the building I presume that sit-in type (as opposed to sit-on type) solar panels are proposed because these typically give a far better level of finish.

Regards  
Andrew

**Andrew Smith**  
**Planning Assistant**  
**Lake District National Park Authority**  
**01539 792660**  
[www.lakedistrict.gov.uk](http://www.lakedistrict.gov.uk)