

Permit Reference: JP3132LH

Operator: Waste Gas Technology UK Ltd

Installation: Isle of Wight Energy from Waste

Form Number: Agency Form / JP3132LH / WU1 / Form dated 07/11/2006

Reporting of Water Usage for the year 2014

Water Source	Usage (m ³)	Specific Usage (m ³)
Mains water	56,451 m3	53,199 m3
Site borehole		
River abstraction		
TOTAL WATER USAGE	56,451 m3	

Trends in Water Usage			
Year	Named Water source	Total Water usage	Water per unit output
2009	Mains	51,564 m3	93.16 KW/m3
2010	Mains	28,314 m3	122.81 KW/m3
2011	Mains	59,365 m3	119.85 KW/m3
2012	Mains	46,406 m3	7.725 ltrs/kW
2013	Mains	55,330 m3	7.16 ltrs/kW
2014	Mains	56,451 m3	7.17 ltrs/kW

Operator's comments :

1. The total water used on site for Process and Domestic usage, was 56,451 m3
2. The Specific Water Usage detailed above, was that for Cooling Tower evaporative losses of 53,199 m3

Signed *Karl Hardy*

Date 10.01.15

(Authorised to sign as representative of the Operator)