



CITY OF
WORCESTER

Making Worcester a
Great Place to
Live, Work and Visit

REPORT OF HEALTH AND SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool Registered Office Address: Leisure Centre Ltd
Address: * Sunningdale Potton House, Potters Park Rd
Worcester, WR1 1NL Redditch, MK44 3AL
 Tel: 01905 211111 Tel: 01905 211111

I have carried out an inspection at the above address* and identified matters that you should attend to in order to comply with health and safety law. Inspection is a means of sampling compliance without necessarily being comprehensive. The responsibility for ensuring the health and safety of employees and others from risks which may arise from the conduct of your business rests with you. This confirms my verbal advice but, if you wish, you may request a letter explaining in more detail what needs to be done, when and why. This is not a statutory enforcement notice.

As agreed with the person seen during this visit, the time that these matters must be complied with is 1 month or as stated below. except item ①

Legislation Code (see over)	ITEM Areas Inspected: Whole / Part (Specify)
1/314	The remaining Health and Safety issues (that were discussed) are: ① I understand the spring board and the diving stand columns are <u>carved</u> and must not be used. During the visit I have noted there are no signages on these equipments. <u>across</u> the diving stand is only restricted with rope on the staircase. I am not satisfied <u>equipment</u> in the actions taken to isolate these areas. I have noted a "warning board" stating the spring board usage and the swimming instructor's discussions with Mr. Ralph and with on board. As agreed, the staircase leading (first part) of diving structure

Advisory leaflets given:

A Guide to Health and Safety At Work ☐
 Five Steps to Risk Assessment ☐
 Other ☐ (Specify)

What to expect when a health and safety inspector calls ☐
 RIDDOR Explained ☐

Further action to be taken by the Authority:

This report only ☐ Letter ☐ Improvement/Prohibition Notice ☐ Other ☐ (Specify) Letter to check compliance

Inspector's name: Peter Niah
 Inspector's signature: [Signature]
 Inspector's tel. (01905) 72: 7574
 Date: 21/1/03 Time:

Person(s) seen: June Adams
 Position: Pool Manager
 Signature: [Signature]

If you think the action required by this report is not justified you should make representations to my Manager: Mrs A L Fletcher, within two weeks on telephone number (01905) 722224 or in writing to the address below.

Please note that in circumstances where public health or public safety is affected the Council may be obliged to disclose to a third party information contained in this report under the provisions of the Freedom of Information Act 2000.

Martin Gillies Environmental Health Manager
 The Guildhall, High Street, Worcester, WR1 2EZ
 Tel: 01905 723471 Fax: 01905 722255
 Minicom: (text telephone for the hearing impaired) 01905 722156
 www.cityofworchester.gov.uk



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool, S. W. 1000 Walk

Date: 21/4/2008

Legislation Code(see over)	ITEM
	<p>is to be removed and the Spring board to be "cut" off at the end preventing unauthorized access to these equipment.</p> <p>This to be done <u>within 14 days</u>.</p> <p>Temporary measures: Such as signage, lifeguard vigilance, all instructions are informal not to allow swimmers use the Spring boards, etc.</p>
3	<p>② Reviews and Review Risk assessment, so they are site specific to this premises. i.e. Staff canteen area, and Fire safety etc. Young persons (Rich), etc.</p>
4	<p>③ Vinyl floor has started to lift in corners (balcony area) creating potential trip hazard. Please assess and take appropriate action.</p>
1	<p>④ Have confirmed the large panel of glass found in the Balcony and dance studio are made of toughened glass.</p> <p>⑤ Recommend all sockets are covered (Child Safety), preventing children accessing any "live" parts.</p>
12/4	<p>⑥ I understand a weight rack to be installed in the Dance studio storage.</p> <p>⑦ There are trailing cables in the office that needs to be secured, preventing potential trip hazards.</p>
4	<p>⑧ Repair/Replace the missing roof panel in the Men's changing room.</p>
1	<p>⑨ Thoroughly clean the lime scale found on the pipes in the Men's shower room.</p>
1/4	<p>⑩ Noted extensive debris at the bottom of the pool, particularly in corner of the pool. ^{and subaqueous} Please clean these areas regularly.</p>

Inspector's signature: *[Signature]*Received by: *[Signature]*

www.worcester.gov.uk

Location: Environmental Health, Orchard House, Farrier Street, WR1 3BB

Typetalk: 18001 01905 722233

DX: 716287

Page 2 of 2



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool, Sansone Walk, WR1 1NU

Date: 21st 06/08.

Legislation Code(see over)	ITEM
4	⑪ Check ^{Check} lighting in the Sauna Room. Ensure there are sufficient lighting in the Sauna room.
1/3	⑫ Provide a "Emergency exit" signage in the Sauna Room.
4	⑬ Replace the door in the toilet area, near the Sauna Room.
1	⑭ There was evidence that people/person are smoking in the premises. Please ensure all persons are aware of the 'No smoking legislation. Ensure there are adequate signage and effective monitoring by staff.
4	⑮ There are "leaky" taps found in the men's changing room please repair.
18	⑯ The electrical distribution board found in the pool storeroom is not well satisfactorily protected as wires are sagging / splashing onto the electrical components. A discussion these equipment needs to be assessed and appropriate action taken. Please lock door at all times.
1/3	⑰ Provide Shoe covers (uniform), preventing infection etc.
	⑱ Land around the Steam Room and Health suite are to undergo refurbishment. There was an access to the steam room.
1/3	⑲ Isolate the plant Room, so only authorised person are allowed on these areas. All cleaning agents to be removed to another area.
19	⑳ Please send us a copy of Gas Safety Certificate (recent) ㉑ Highly recommend the Health and Safety training officer undergo

Inspector's signature:

Received by:

www.worcester.gov.uk

Location: Environmental Health, Orchard House, Farrier Street, WR1 3BB

Typetalk: 18001 01905 722233

DX: 716287

Page 3 of 4

11.10am - Signage on spring board has now been placed



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool, Sunnyside Walk Date: 21st Feb 2008
Worcester

Legislation Code(see over)	ITEM
1/2	<p>21) Please ensure all staff including the Health and Safety Monitoring officer has suitable and sufficient Health and Safety training to carry out their roles.</p> <p>I understand the Health and Safety monitoring officer has a basic health and safety course and covered 63 problems.</p> <p>I highly recommend an "advanced" health and safety course for this officer.</p>
C4	<p>22) Extensive yellow tile damages found in main pool, creating potential risk of "cut" hazards (particularly to swimmers/floors repair/replace).</p>
1/4	<p>23) Remove the item in front of the electrical distribution board in pool store room, easy access to isolation switch (Emergency).</p>
1/3/4	<p>24) I have noted the vacuum ^{pump} is damaged and cannot be used effectively. I understand staff has to "dip" dive in order to clean the pool on a regular basis.</p> <p>The effectiveness or suitability of the vacuum pump has been discussed in my previous visits.</p> <p>I am not satisfied in the effectiveness or suitability of this vacuum pump and a suitable vacuum pump needs to be used as part of your Safe System of work. Highly recommend an electronic vacuum pump, so it is more effective and reduces manual handling to staff (library of controls).</p>

Inspector's signature: [Signature] Received by: [Signature]

www.worcester.gov.uk

Location: Environmental Health, Orchard House, Farrier Street, WR1 3BB

Typetalk: 18001 01905 722233

DX: 716287

Page 4 of 4



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool Registered Office Address: _____
 Address*: Sunshine Walk _____
Worcester WR1 1NU _____
 Tel: 202 _____ Tel: _____

I have carried out an inspection at the above address* and identified matters that you should attend to in order to comply with health and safety law. Inspection is a means of sampling compliance without necessarily being comprehensive. The responsibility for ensuring the health and safety of employees and others from risks which may arise from the conduct of your business rests with you. This confirms my verbal advice but, if you wish, you may request a letter explaining in more detail what needs to be done, when and why. This is not a statutory enforcement notice.

As agreed with the person seen during this visit, these matters will be dealt with by As discussed - immediately or as stated below.

Legislation Code (see over)	ITEM	Areas Inspected: Whole / Part (Specify)
1/4		Further to the visit, I am disappointed in the poor cleaning standard in the Deep pool area. There was extensive debris inside the pool and photographs have been taken to demonstrate this. I understand the pool has not been cleaned since 6.30 am. I noted the debris (bundle of hairs etc) at 10.55 am. I understand this is to be cleaned immediately.
1		I left a copy of the Improvement Notices for attention of the employees.
1		I have also noted the Spring board and the staircase has been removed from the diving areas.

Leaflets given:

- A Guide to Health and Safety At Work ☐ What to expect when a health and safety inspector calls ☐
 Five Steps to Risk Assessment ☐ RIDDOR Explained ☐

Other ☐ (Specify) _____

Further action to be taken by the Authority:

This report only ☐ Letter ☐ Improvement/Prohibition Notice ☐ Other ☐ (Specify)
 Inspector's Name: Rozan Miah Received by (Print Name): Jamie Adams
 Inspector's signature: [Signature] Position: Duty Manager
 Inspector's tel. (01905) 72 574 Signature: [Signature]
 Date: 6/9/08 Time: 11.10

If you think the action required by this report is not justified you should make representations to my Manager: Mrs A L Fletcher, within two weeks on telephone number (01905) 722224 or in writing to the address below. Please note that in circumstances where public health or public safety is affected the Council may be obliged to disclose to a third party information contained in this report under the provisions of the Freedom of Information Act 2000.



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool, Sandome Walk, WR1 1NU Date: 20th February 2008

Legislation Code(see over)	ITEM
	and has not completed on-going training IPL Standard.
	I am also disappointed in the Lifeguard Trainee, as he is not completing the training records for all life guards nor is he following the lifeguarding criteria for ongoing training and competency assessment.
	There are also poor record keeping and records has not been reviewed (reviewed for current "life guards" (Numbers ^{of} has left the company).
	However, there are three competent life guards: -
	① Rich Prokwell
	② Dave Fisher.
	③ Dan Allen.
	I appreciate your immediate actions, in <u>VOLUNTARILY</u> removing the "lifeguards" on the pool that are not competent. I understand Dave Fisher is the overall life guard on site at the moment.
1/3/4	I am not satisfied with the temporary plastic mesh on the balcony area (pool) and noted defects in many areas. You need to assess the suitability of the temporary structure (and wind) and take appropriate action. Defective chair has also been removed. Formal Notices to be served.

Inspector's signature

Received by

www.worcester.gov.uk

Location: Environmental Health, Orchard House, Farrier Street, WR1 3BB

Typetalk: 18001 01905 722233

DX: 716287

Page 3 of 2

REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Proprietor's Copy

Premises: Worcester Swimming Pool

Registered Office Address:

Address*: Sansone Walk

Worcester

Tel: 01905 20294

Tel:

I have carried out an inspection at the above address* and identified matters that you should attend to in order to comply with health and safety law. Inspection is a means of sampling compliance without necessarily being comprehensive. The responsibility for ensuring the health and safety of employees and others from risks which may arise from the conduct of your business rests with you. This confirms my verbal advice but, if you wish, you may request a letter explaining in more detail what needs to be done, when and why. This is not a statutory enforcement notice.

As agreed with the person seen during this visit, these matters will be dealt with by 1 month, or as stated below.

Legislation Code(see over)	ITEM	Areas Inspected: Whole / Part (Specify)
		Further to the report, 1 note action has been taken in response to the report 18th May 2009.
		As discussed, you need to renew the cleaning schedule monitoring; noted body fat (scum line on main pool in parts, demonstrating cleaning not done effectively).
II	Need to assess the chemical products (cleaning). As discussed, the present cleaning products may not be effective, in light of previous visits/complaints regarding scum line in pools, body fats in shower area and changing rooms.	

Advisory leaflets given:

A Guide to Health and Safety At Work

☐ What to expect when a health and safety inspector calls

Five Steps to Risk Assessment

☐ RIDDOR Explained

Other ☐ (Specify)

Further action to be taken by the Authority:

This report only ☐ Letter ☐ Improvement/Prohibition Notice ☐ Other ☒ (Specify)

Inspector's Name: Raza Khan

Received by (Print Name): IAN STED

Inspector's signature: [Signature]

Position: CONTRACT MANAGER

Inspector's tel (01905) 72 2574

Signature: [Signature]

Date: 5/6/09 Time:

If you think the action required by this report is not justified you should make representations to my Manager: Mrs A L Fletcher, within two weeks on telephone number (01905) 722224 or in writing to the address below. Please note that in circumstances where public health or public safety is affected the Council may be obligated to disclose to a third party information contained in this report under the provisions of the Freedom of Information Act 2000.



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool, Sansome Walk. Date: 17th May 2009
Worcester WR1 1NU.

Legislation Code(see over)	ITEM
4	(3) tap in Mens changing room is defective and needs to be rectified.
1	(4) Extensive lime scales found on the men's shower pipes, that requires cleaning.
1	(5) There was excessive debris found on the floor of near steam room lounge
1	(6) Please send me a copy of the cleaning schedule and the water test results for today. I note there is no cleaning schedules for the main pool area, and Teaching Pool and main changing rooms. The only schedule available ^{covers other} is for other areas except for above.
	(7) I note the water test results (automatic dosing) is satisfactory and within the parameters (free chlorine, ph and water temp).
1/4	(8) ^{conductors} the lighting are defective/damaged and needs to be assessed for its suitability.

Inspector's signature.....

Received by.....

www.worcester.gov.uk

Location: Environmental Health, Orchard House, Farrier Street, WR1 3BB

Typetalk: 18001 01905 722233

DX: 716287

Page 2 of 2



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Proprietor's Copy

Premises: Worcester Swimming Pool and Fitness Centre

Registered Office Address: Leisure Connection Contractors

Address*: Sanjomonwalk, Worcester WR1 1NU

Tel: 20241

Tel:

I have carried out an inspection at the above address* and identified matters that you should attend to in order to comply with health and safety law. Inspection is a means of sampling compliance without necessarily being comprehensive. The responsibility for ensuring the health and safety of employees and others from risks which may arise from the conduct of your business rests with you. This confirms my verbal advice but, if you wish, you may request a letter explaining in more detail what needs to be done, when and why. This is not a statutory enforcement notice.

As agreed with the person seen during this visit, these matters will be dealt with by VOLUNTARILY or as stated below.

Legislation Code(see over)	ITEM	Areas Inspected: Whole / Part (Specify)
		Further to the visit in response to complaints, the following actions / attentions has been taken:
1		① There are excessive body fat / scum around the main and teaching poolside with excess levels of debris found at bottom of main pool and around the corners for both pools. I appreciate your immediate actions in isolating the affected or "worst" areas and appropriate cleaning was undertaken by staff. Those areas would not be used by user until such times, there is a adequate system of effective cleaning. The closure of these areas were done voluntarily by yourself.
		② I note, instructors are present with the children and there is 1 lifeguard in the main pool and another in teaching pool.

Advisory leaflets given:

A Guide to Health and Safety At Work
Five Steps to Risk Assessment

☐ What to expect when a health and safety inspector calls
☐ RIDDOR Explained

Other ☐ (Specify)

Further action to be taken by the Authority:

This report only ☐ Letter ☐ Improvement/Prohibition Notice

☐ Other ☒ (Specify)

Inspector's Name: LARA MIAH

Received by (Print Name): DRITAN TABAKU

Inspector's signature: [Signature]

Position: Head life guard / Duty Manager

Inspector's tel. (01905) 72 2574

Signature: [Signature]

Date: 18/5/09 Time: 8.15pm

If you think the action required by this report is not justified you should make representations to my Manager: Mrs A L Fletcher, within two weeks on telephone number (01905) 722224 or in writing to the address below. Please note that in circumstances where public health or public safety is affected the Council may be obligated to disclose to a third party information contained in this report under the provisions of the Freedom of Information Act 2000.



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool
 Address*: Sansome Walk, Worcester
WR1 1NU.
 Tel: 20241

Registered Office Address: Leisure Connection
Potten House, Wyboston Lakes.
Wyboston, Bed.
 Tel:

I have carried out an inspection at the above address* and identified matters that you should attend to in order to comply with health and safety law. Inspection is a means of sampling compliance without necessarily being comprehensive. The responsibility for ensuring the health and safety of employees and others from risks which may arise from the conduct of your business rests with you. This confirms my verbal advice but, if you wish, you may request a letter explaining in more detail what needs to be done, when and why. This is not a statutory enforcement notice.

As agreed with the person seen during this visit, these matters will be dealt with by 1 month or as stated below.

Legislation Code(see over)	ITEM	Areas Inspected: Whole / Part (Specify)
		Further to the Health and Safety Inspection, I am satisfied in the general standard at time of visit. Noted the significant improvement in the safe system of works procedures and documentations.
1/4		As discussed the following require your action / attention: — ① Please send a copy of the Structural (Conditions) Engineer report. Noted number of cracks on structural pillars and walls
4		② Window frame between fitness area and pool was rotten wood and may not be easily cleared. Please amend with smooth surface.
4		③ Noted a number of areas with Scumline around the pool area, ^{extensive} and debris and in changing room (lockers / cubicles) I appreciate your immediate response in cleaning these areas. You need to regularly monitor / supervise vulnerable areas where cleaning is required on a regular basis.

Advisory leaflets given:

A Guide to Health and Safety At Work
 Five Steps to Risk Assessment

☐ What to expect when a health and safety inspector calls
☐ RIDDOR Explained

Other ☐ (Specify)

Further action to be taken by the Authority:

This report only ☐ Letter ☐ Improvement/Prohibition Notice ☐ Other ☒ (Specify)

Inspector's Name: KAZA NIAH

Received by (Print Name): DAN STEED

Inspector's signature: [Signature]

Position: Contract Manager

Inspector's tel. (01905) 72... 2574

Signature: [Signature]

Date: 20/8/09 Time:

If you think the action required by this report is not justified you should make representations to my Manager: Mrs A L Fletcher, within two weeks on telephone number (01905) 722224 or in writing to the address below. Please note that in circumstances where public health or public safety is affected the Council may be obligated to disclose to a third party information contained in this report under the provisions of the Freedom of Information Act 2000.



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool, Sangemo Walk Date: 20th Aug '09.
WR1 1ND.

Legislation Code(see over)	ITEM
	In light of the number of Complaints, frequent cleaning would be required in busy time periods and be at an acceptable standard at all times. Team changing to be refurbished.
4	(4) Ensure there are sufficient levels ventilation levels in the Men's and Ladies changing toilets areas, sufficient number of air changer per hour to extraction
4	Ensure there are sufficient lighting level in Men's toilet.
1/18	(5) Ensure the building is protected (lead- roofing) from any lightning (Electrical (water hazards), noted number of lead plating strips on wall/ground are damaged.
1/3	(6) Ensure all staff including Duty Manager have sufficient health and Safety training to carry out their role. (updated the training is being reviewed/revised)
1/4	(7) I note a safe system of work (procedures are implemented for the pool water dosing and relevant actions are carried out and monitored (PPE usage).
4	(8) Appropriate immediate response in removing the table on the balcony, prevent persons (children) falling over balcony.
4	(9) Fix the roof leak in changing reception.
4	(10) Investigate the ventilation level in the Steam room (Jacuzzi)
4	(11) Repair the walls in disabled toilet.

Inspector's signature: [Signature] Received by: [Signature]

www.worcester.gov.uk

Location: Environmental Health, Orchard House, Farrier Street, WR1 3BB

Typetalk: 18001 01905 722233

DX: 716287

Page 2 of 2

Company Secretary of
Leisure Connection Limited
Potton House
Great North Road
Wyboston
Bedford
MK44 3AL

This matter is being dealt with by R Miah

on direct line (01905) 722574
Fax: (01905) 722255
E-mail: rmiah@worcester.gov.uk

Our ref: EH/RM/EF/PF
Your ref:

Date: 5th March 2008

Dear Sir / Madam

WORCESTER SWIMMING POOL, SANSOME WALK, WORCESTER. WR1 1NU

Further to my visit to the above premises on 20th February 2008 and my telephone conversation with Dave Pugh, Operational Manager on 29th February 2008, I have noted various health and safety issues that were discussed along with Paul Read, Company Health and Safety monitoring officer.

Please find enclosed, the following Notices serial number:-

1. EH/RM/2039/08 Improvement Notice
2. EH/RM/2040/08 Improvement Notice

I draw your attention to the enclosed appeals procedures notices.

All company employees are entitled under S28 of the Health and Safety at Work etc Act 1974 to be made aware of the contents of this letter and the Improvement Notices. I have therefore sent a copy of this letter and the notices addressed to them and this must be brought to their attention.

Cont'd.....

www.worcester.gov.uk

Location: The Guildhall, High Street, Worcester WR1 2EY

Typetalk: 18001 01905 722233 **DX:** 716287




- 2 -

I will revisit the premises following expiry of the Improvement Notices on 7th April 2008, when I shall expect the Company to have complied with the actions required. If not, further legal action may follow i.e. prosecution for failure to comply with these notices.

Should you wish to extend the period required for compliance the request must be made in writing and give reasons as to why you wish to extend the period of compliance.

Yours faithfully



RAZA MIAH M.Med Sc., M.Sc., CMIOSH (RSP)
Health & Safety Inspector
Environmental Health

Encs: Statutory Notices
1. EH/RM/2039/08
2. EH/RM/2040/08

CC. Copy of Statutory Notices to Employees.

Sections 22,23, and 24

IMPROVEMENT NOTICE

Schedule of Works

Compliance with this Notice may be achieved by:

Determine what arrangements are appropriate to ensure that the introduction of those preventative and protective measures is effectively planned. You should also determine what arrangements are appropriate to ensure the effective organisation, control, monitoring and review of the preventive and protective measures

The areas to be covered should include the following issues:

- ✓ - suitable and sufficient Health and Safety training for all staff, particularly life-guards
- review and revision of risk assessments (where appropriate) and relevant action taken
- cleaning equipment are kept in good condition and operable at all times

and

you should implement these arrangements.

Alternatively, any other equally effective steps can be taken.

This schedule forms part of Notice No. EH/RM/2040 dated 5th March 2008 in respect of Worcester Swimming Pool, Sansome Walk, Worcester WR1 1NU.

A handwritten signature in black ink, appearing to read 'R. G. Smith', is written over a horizontal line.

Sections 22, 23 and 24

IMPROVEMENT NOTICE

Schedule of Works

1. Make a suitable and sufficient assessment of the risks to the health and safety;
 - a) of your employees to which they are exposed whilst they are at work and
 - b) of persons not in your employment arising out of or in connection with the conduct of your undertaking
2. Record the significant findings of the assessment.
3. At minimum the assessments should include the following:
 - Risk of falls of person (including children) and items from the main pool balcony
 - Employee competency in Health and Safety
 - Employment of young person
 - Trip hazards found in the balcony areas, access routes and offices (trailing cables),
 - Staff and public welfare – algae and debris found in the main pool
 - Selection of suitable cleaning equipment i.e electronic vacuum pump
 - Electrical safety of building including the main pool store room
 - Maintaining wall tiles in the main pool area in good repair.

This Schedule forms part of Notice No: EH/RM/2039/08 dated 5th March 2008 in respect of Worcester Swimming Pool, Sansome Walk, Worcester WR1 1NU.





REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: WORCESTER SWIMMING POOLRegistered Office Address: LEGHURST COMMERCIAL LTDAddress*: SANDOME WAYBITES HOUSE, WEBSTON LANE,WORCESTERWEBSTONTel: 01905 20241

Tel:

I have carried out an inspection at the above address* and identified matters that you should attend to in order to comply with health and safety law. Inspection is a means of sampling compliance without necessarily being comprehensive. The responsibility for ensuring the health and safety of employees and others from risks which may arise from the conduct of your business rests with you. This confirms my verbal advice but, if you wish, you may request a letter explaining in more detail what needs to be done, when and why. This is not a statutory enforcement notice.

As agreed with the person seen during this visit, these matters will be dealt with by 1 month except ① or as stated below.

Legislation Code(see over)	ITEM	Areas Inspected: Whole / Part (Specify)
		Further to the Health and Safety inspection the following requires your action (attention):
1/4	①	The Emergency button/alarms were not working during inspection in the Sauna and Steam room. You have voluntarily agreed to isolate the Sauna and Steam room until there is a safe system in an emergency. I understand that an electrician has been called out to rectify the emergency alarms, trip devices and place the control panel in a suitable location. I also understand that panic alarms in disabled toilets remain working and these areas
4	②	The bulb inside the sauna is out of order and needs to be replaced, so there is sufficient levels of lighting
4	③	The ceiling lights near the Sauna is also out of order and needs to be rectified, so there is sufficient levels of lighting

Advisory leaflets given:

A Guide to Health and Safety At Work

☐ What to expect when a health and safety inspector calls

Five Steps to Risk Assessment

☐ RIDDOR ExplainedOther ☐ (Specify)

Further action to be taken by the Authority:

This report only ☐ Letter ☐ Improvement/Prohibition Notice ☐ Other ☐ (Specify)Inspector's Name: RAZA MUHAMMADReceived by (Print Name): DAVE PUGHInspector's signature: [Signature]Position: Contract ManagerInspector's tel. (01905) 72 2574Signature: [Signature]Date: 21/3/11 Time:

If you think the action required by this report is not justified you should make representations to my Manager: Mrs A L Fletcher, within two weeks on telephone number (01905) 722224 or in writing to the address below. Please note that in circumstances where public health or public safety is affected the Council may be obliged to disclose to a third party information contained in this report under the provisions of the Freedom of Information Act 2000.



REPORT OF HEALTH & SAFETY INSPECTION/VISIT

Premises: Worcester Swimming Pool, Sarsome Walk, Worcester WR1 1NU, Date: 21/3/11

Legislation Code (see over)	ITEM
1/3	① I understand the "new" Operational Manager has no formal health and safety training. A course has been arranged, so Operational Manager can attend. Ensure all staff have suitable and sufficient health and safety training.
4	② There are extensive peeling paint and mould ^{near} the steam room area. Investigate and take appropriate action (Occupational Health)
4	③ noted extensive scaling on shower (men) I understand this is to be cleaned.
4	④ I understand the Scum line in Main pool is to be cleaned as ongoing programme.
4	⑤ Replace the cracked wall tiles in Main pool area, prevent cut injury, particularly to children.
4	⑥ I understand the ^{Window} Notice Board (Misty) in main pool is to be repainted (Occupational Health)
4	⑦ The Teaching pool Store room is to be locked off all times and remove the defective ceiling tile.
4	⑧ The Gym cupboard needs to be locked (Electrical hazards) and install a light suitable lighting.
18	⑨ I understand the plate cover to be placed over the electrical wires on the landing of Health Suite.

Inspector's signature: *[Signature]* Received by: *[Signature]*