
From: O'Shea, David
Sent: 10 May 2017 16:02
To: 'Endersby, Karl'; McCart, Gemma
Cc:
Subject: RE: Brislands Lane Phase 2 S278 Works

Hi Karl,

Apologies for not getting back to you.

Happy with the extent of surfacing, however I am concerned about planning off the existing carriageway surface. Firstly I'm not sure what the existing makeup is? Imagine the thickness is not significant. In addition, during the works, serious concern was raised by the resident at the property on the southern side of Brislands Lane, in that any mechanical dig was affecting his house foundations. Therefore, I think overlaying the existing carriageway surface would be a better option than an inlay, primarily to avoid any full carriageway reconstruction works.

With regards to a works start, if you could get your contractor to supply their proposed TM, programme and anticipated works start date. Imagine a road closure will be required?

Regards
Dave

David O'Shea
Senior Highway Engineer

Engineering Consultancy
Hampshire County Council
The Castle
Winchester
SO23 8UD

E-mail: david.oshea@hants.gov.uk

Web: www.hants.gov.uk/sharedexpertise

[Copyright](#) Hampshire County Council 2004 [Disclaimer](#) [Privacy Statement](#)

From: Endersby, Karl [<mailto:karl.endersby@persimmonhomes.com>]

Sent: 08 May 2017 14:37

To: McCart, Gemma; O'Shea, David

Subject: RE: Brislands Lane Phase 2 S278 Works

Importance: High

Dear Gemma/David,

Can you please confirm your agreement or otherwise to the extent of re-surfacing proposed to Brislands Lane in order that we can finalised the works order with our contractor and seek to get the works scheduled with your streetworks team.

Thanks in advance.

Regards

Karl Endersby
Technical Director

Persimmon Homes South Coast
Parkview House
100 Wickham Road
Fareham
PO16 7HT

karl.endersby@persimmonhomes.com
www.persimmonhomes.com
