




Health Protection Agency
Food, Water & Environmental Microbiology Network (Chelmsford Laboratory)
Broomfield Hospital
Court Road, Chelmsford CM1 7ET
Tel: 01245 514045 / 514270
Fax: 01245 514584



a UKAS accredited testing laboratory No. 1734

TEST REPORT

EXECUTIVE MANAGER
ENV. & CULTURAL SERVICES
UTTLESFORD DIST. COUNCIL
LONDON RD. SAFFRON WALDEN
ESSEX CB11 4ER

Page 1 of 1

Lab Reference No. I,10.0011659.N Date/time collected 08.09.10 11:00 Date/time received 08.09.10 14:15

Place of sampling/identification LORD BUTLER LEIS.

Specimen type WATER Swimming pool

Senders Ref KH37/10 Date tested 08.09.10

Method Ref	Test	Results
W02	Total coliforms/100ml	not detected
W02	Escherichia coli/100ml	not detected
W04	Aerobic colony count/ml at 37C after 24 hrs	nil detected
W07	Ps aeruginosa/100ml	not detected

Comments SATISFACTORY

Authorized by : Amor Waters (Food Examiner)

Date of issue 13.09.10

Where * appears in the method reference column this indicates that the test method is not UKAS accredited.
Opinions and interpretations expressed in this report and any results from reference laboratories are outside the scope of UKAS accreditation for this laboratory.