



Health Protection Agency  
Food, Water & Environmental Microbiology Network (Chelmsford Laboratory)  
Broomfield Hospital  
Court Road, Chelmsford CM1 7ET  
Tel: 01245 514045 / 514270  
Fax: 01245 514584

a UKAS accredited testing laboratory No. 1734

TEST REPORT



Page 1 of 1

EXECUTIVE MANAGER  
ENV. & CULTURAL SERVICES  
UTTLESFORD DIST. COUNCIL  
LONDON RD. SAFFRON WALDEN  
ESSEX CB11 4ER

Lab Reference No. I,11.0000309.T      Date/time collected 12.01.11 12:10      Date/time received 12.01.11 14:00

Place of sampling/identification DUNMOW

Specimen type WATER      Swimming pool

Senders Ref KH62/10      Date tested 12.01.11

Method Ref	Test	Results
W02	Total coliforms/100ml	not detected
W02	Escherichia coli/100ml	not detected
W04	Aerobic colony count/ml at 37C after 24 hrs	nil detected
W07	Ps aeruginosa/100ml	not detected

Comments SATISFACTORY

Date of issue 14.01.11

Authorized by : Martin Lodge (Food Examiner)

Where \* appears in the method reference column this indicates that the test method is not UKAS accredited.  
Opinions and interpretations expressed in this report and any results from reference laboratories are outside the scope of UKAS accreditation for this laboratory.