

From: [REDACTED]
Sent: 18 September 2012 10:06
To: Peter Dodd
Cc: Callum MacDonald
Subject: RE: WSE nomenclature

Good morning Peter;

We have received clarification from Allianz Engineering in relation to the 'Plant No's' referred too in the Written Scheme.

The major items refer to 'asset numbers' and are distinguished by each stream or boiler, for example 300V101 and 300V201 in reference to the water tube boilers themselves.

Associated pressure pipework prefixed by 150, 300, 200, 800 etc refer to the drawing numbers from the P&ID's for existing pipe runs.

P numbers are plant numbers where packages were supplied by individual manufacturers, for example P028 is the condenser supplied by Hamworthy.

Each of the 'plant' items numbered has an examination procedure (individually numbered and laid out in the back of the WSE) some of these also have an 'written inspection procedure' detailing where to find the items and how to carry out the inspection.

In conclusion we are confident that when the next examinations are due that we will be able to provide a 'first time' visitor with the direction required to carry out his assessment satisfactorily.

Regards

Scotgen (Dumfries) Ltd
tel 01387 24 00 66

This email was received from the INTERNET and scanned by the Government Secure Intranet anti-virus service supplied by Cable&Wireless Worldwide in partnership with MessageLabs. (CCTM Certificate Number 2009/09/0052.) In case of problems, please call your organisation's IT Helpdesk.

Communications via the GSi may be automatically logged, monitored and/or recorded for legal purposes.