



GREENS

Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Registered No. 5067893

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

EC DECLARATION OF CONFORMITY

Greens Power Reference No: OVL3036A

Client: Ascot Environmental Limited
Client Purchase Order Ref: 27746 Job No. 06/409
Project: 2 off Waste Heat Boilers (W2E) Dargavel

Description of Goods:-

The manufacture of the following items:-

2 off Boiler Sets comprising:

Primary Evaporator
Secondary Evaporator
Primary Superheater
Secondary Superheater
Economiser

We hereby certify that the above equipment has been manufactured in accordance with BS EN 12952 and the Pressure Equipment Directive 97/23/EC and the requirements specified by the contract documents.

FOR GREENS POWER LIMITED

NAME (PRINT)

POSITION:

SIGNATURE

DATE

Notifying Body: Lloyds

OVF043/2



Inspection Certificate

Project **Ascot Environmental Ltd.**
(Order 27746 Job No. 06/409)
2 off Waste Heat Boilers (W2E), Dargavel

Client **Greens Power Limited**
Raines House, Denby Dale Road,
Wakefield, WF1 1HR, England

Office **Coventry**

Client's Order Number **A8396; OVL3036A**

Date **02 March 2012**

Order Status **Complete**

Inspection Dates

First **31 May 2011**

Final **27 February 2012**

This certificate is issued to **GREENS POWER LIMITED.**, to certify that the undersigned did at their request attend their workshop in Calder Vale Road, Wakefield, for the purpose of examining the items listed below, manufactured to Works Order No. OVL3036A: -

Description: **2 off Waste Heat Boilers (W2E), each comprising:-**

Primary Evaporator
Secondary Evaporator
Primary Superheater
Secondary Superheater
Economiser

Code: **BS EN 12952: 2001 & the Pressure Equipment Directive 97/23/EC, Module G**

Drawings: **OVL3036-01 Rev. B and sub-level drawings as per Design Appraisal Document**

The following examinations were carried out in accordance with Code & ITP No. OVL3036A/ITP1 Issue D: -

1. Review of Design Appraisal Document: COV1112456 O-23387/PKC dated 19 October 2011 Issue 1 refers
2. Review of Weld Index Sheet
3. Review of Welding Procedures, Procedure Qualifications and Welder Qualifications
4. Identification of materials and review of certification
5. Monitor fabrication
6. Review of NDE results
7. Witness of unit hydrostatic pressure tests at 118 barg (Primary Evaporators); 147.1 barg (Secondary Evaporators); 142.8 barg (Primary/Secondary Superheaters); and 144.8 barg (Economisers)
8. Verify calibration status of test equipment used
9. Final Inspection
10. Review stamping of nameplates
11. Review of documentation

All of the above was carried out to the satisfaction of the undersigned. On the basis of the scope of inspection undertaken, the equipment has been found to comply with specification requirements

For identification purposes the nameplates were stamped: 'iLRs'



M J Lucas
For self and on behalf of J M Lack, E K Darley, R Johnson
Surveyors to Lloyd's Register EMEA

A member of the Lloyd's Register Group

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

INDEX

VOLUME 1

DECLARATION OF CONFORMITY

- 1 INSPECTION AND TEST PLAN
- 2 HYDRAULIC PRESSURE TEST CERTIFICATES
- 3 HEADERS MATERIALS WELDING NDE
 - 3.1 Boiler No.1
 - 3.2 Boiler No.2
- 4 BALL TEST RECORD
- 5 WELDING CONSUMABLES ISSUE LOG
 - 5.1 WELDING CONSUMABLES CERTIFICATES
- 6 VISUAL WELD INSPECTION FOR UNITS CERTIFICATE
- 7 PRESSURE GAUGE CALIBRATION CERTIFICATE
- 8 UNIT WELD IDENTIFICATION – HEADER END
 - 8.1 BOILER NO.1 & 2 – ECONOMISERS
 - 8.2 BOILER NO.1 & 2– SECONDARY EVAPORATORS
 - 8.3 BOILER NO.2 – PRIMARY EVAPORATORS
 - 8.4 BOILER NO.1 – PRIMARY EVAPORATORS
 - 8.5 BOILER NO.1 – SUPERHEATERS
 - 8.6 BOILER NO.2 – SUPERHEATERS
- 9 INSPECTION OF WELDED GILL FINNED COILS
 - 9.1 BOILER NO.1-SECONDARY EVAPORATOR & ECONOMISER
 - 9.2 BOILER NO.2-SECONDARY EVAPORATOR & ECONOMISER
- 10 PLATE FIN TUBES – FINNING INSPECTION/PRODUCTION CONTROL SHEET

27/2/2

- 11 WELDER & RADIOGRAPHY TRACEABILITY SHEET
 - 11.1 PRIMARY EVAPORATOR UNIT WELDS
 - 11.2 SECONDARY EVAPORATOR UNIT WELDS
 - 11.3 SUPERHEATER UNIT WELDS
 - 11.4 PRIMARY EVAPORATORS-HAIRPINS
 - 11.5 ECONOMISER UNIT WELDS
 - 11.6 COILS-ECONOMISER & SECONDARY EVAPORATOR
 - 11.7 WPS
 - 11.8 WELD INDEX
 - 11.9 WELDER QUALIFICATIONS
- 12 COMPLETED WELDS – VISUAL INSPECTION RECORDS
- 13 MAGNETIC PARTICLE REPORT
- 14 RADIOGRAPHIC REPORT
 - 14.1 NDE PERSONNEL QUALIFICATIONS
- 15 INSPECTION OF WELDED GILL MASTER ELEMENTS & SAMPLES
- 16 CAST NUMBER TRACEABILITY
- 17 TUBE BEND PROCEDURE QUALIFICATION TEST & BEND INDEX SHEET
- 18 PRODUCTION BEND OVALITY & BEND THICKNESS REPORT
 - 18.1 POST BEND HEAT TREATMENT RECORDS
- 19 PLATE FIN WELDING MACHINE CONTROL SETTINGS
- 20 MATERIAL CERTIFICATES
- 21 DATA PLATES

27/2/2

INDEX

VOLUME 1

DECLARATION OF CONFORMITY

1 INSPECTION AND TEST PLAN

2 HYDRAULIC PRESSURE TEST CERTIFICATES

3 HEADERS MATERIALS WELDING NDE

3.1 Boiler No.1

3.2 Boiler No.2

4 BALL TEST RECORD

5 WELDING CONSUMABLES ISSUE LOG

5.1 WELDING CONSUMABLES CERTIFICATES

6 VISUAL WELD INSPECTION FOR UNITS CERTIFICATE

7 PRESSURE GAUGE CALIBRATION CERTIFICATE

8 UNIT WELD IDENTIFICATION – HEADER END

8.1 BOILER NO.1 & 2 – ECONOMISERS

8.2 BOILER NO.1 & 2– SECONDARY EVAPORATORS

8.3 BOILER NO.2 – PRIMARY EVAPORATORS

8.4 BOILER NO.1 – PRIMARY EVAPORATORS

8.5 BOILER NO.1 – SUPERHEATERS

8.6 BOILER NO.2 – SUPERHEATERS

9 INSPECTION OF WELDED GILL FINNED COILS

9.1 BOILER NO.1-SECONDARY EVAPORATOR & ECONOMISER

9.2 BOILER NO.2-SECONDARY EVAPORATOR & ECONOMISER

10 PLATE FIN TUBES – FINNING INSPECTION/PRODUCTION CONTROL SHEET



- 11 WELDER & RADIOGRAPHY TRACEABILITY SHEET
 - 11.1 PRIMARY EVAPORATOR UNIT WELDS
 - 11.2 SECONDARY EVAPORATOR UNIT WELDS
 - 11.3 SUPERHEATER UNIT WELDS
 - 11.4 PRIMARY EVAPORATORS-HAIRPINS
 - 11.5 ECONOMISER UNIT WELDS
 - 11.6 COILS-ECONOMISER & SECONDARY EVAPORATOR
 - 11.7 WPS
 - 11.8 WELD INDEX
 - 11.9 WELDER QUALIFICATIONS
- 12 COMPLETED WELDS – VISUAL INSPECTION RECORDS
- 13 MAGNETIC PARTICLE REPORT
- 14 RADIOGRAPHIC REPORT
 - 14.1 NDE PERSONNEL QUALIFICATIONS
- 15 INSPECTION OF WELDED GILL MASTER ELEMENTS & SAMPLES
- 16 CAST NUMBER TRACEABILITY
- 17 TUBE BEND PROCEDURE QUALIFICATION TEST & BEND INDEX SHEET
- 18 PRODUCTION BEND OVALITY & BEND THICKNESS REPORT
 - 18.1 POST BEND HEAT TREATMENT RECORDS
- 19 PLATE FIN WELDING MACHINE CONTROL SETTINGS
- 20 MATERIAL CERTIFICATES
- 21 DATA PLATES

27/2/12

From: [REDACTED]
Sent: 03 October 2012 15:22
To: Peter Dodd
Cc: Callum MacDonald
Subject: Scotgen incident 6th August 2012

Attachments: HSE Incident Report for the 6th August 2012 - updated 3rd Oct.docx; T21665 Figure Sheets.pdf; T21665GreensPowerReport.pdf; Investigation commentary GPL.docx
Good afternoon Peter – please find attached the following...

An updated incident report – Alstom appointed and started on site this week.
 Commentary from Greens
 Met lab report and photo images

I have still got an enquiry out with Greens regarding the test certificate for the switch.

The PLC contractor was a company called Industrial Process Control Ltd,

Chris has been to site recently to do some further work and will be carrying out the boiler logic testing before we bring boiler 1 back on line.

That's all for now,

Regards

Scotgen (Dumfries) Ltd

This email was received from the INTERNET and scanned by the Government Secure Intranet anti-virus service supplied by Cable&Wireless Worldwide in partnership with MessageLabs. (CCTM Certificate Number 2009/09/0052.) In case of problems, please call your organisation's IT Helpdesk.

Communications via the GSi may be automatically logged, monitored and/or recorded for legal purposes.

HSE Incident Report Number: 74ABE75EB5 – updated 3rd Oct

Site Location: Scotgen (Dumfries) Ltd.

Dargavel Stores

Off Lockerbie Road

Dumfries

DG1 3PG

Telephone: 01387 240066

Background: Scotgen (Dumfries) is a waste gasification facility; the site has two identical energy recovery lines 'Stream 1' and 'Stream 2'.

Incident Description: On the 6th August 2012 at approximately 13-40hrs a pipe burst occurred on Stream 1. The pipe burst occurred on the outlet pipe from the first evaporative section of the boiler. A decision was made to quench Stream 1 and as a precaution Stream 2 was brought off line whilst the circumstances of the pipe burst could be fully understood. A full investigation was initiated in conjunction with the boiler manufacturers GPL.

The incident was reported to the HSE on-line (Report Number: 74ABE75EB5) on the 7th August 2012 and to SEPA by telephone and e-mail on the 6th August 2012 (Report Number: 0154)

Initial Findings: Preliminary investigations point to the following conclusions-

- Steaming in the first evaporative section and header of Stream 1 which produced steam at a temperature and pressure greater than the design temperature of the pipe work.
- The temperature trip switch TS 3377 did not operate on the system. On independent laboratory testing following the incident the switch failed to initiate within its design criteria.
- Initial visual investigations show no erosion or corrosion within the damaged pipe work.
- A sample of the damaged pipe work will be tested in a metallurgical laboratory to confirm GPL's initial investigation. This report, with some commentary from GPL, is appended here.

Injuries: [REDACTED] suffered a minor injury to his elbow. As a precaution he attended hospital on the evening of the 6th August and returned to work as normal on the 7th August 2012.

Property damage: Pipe work in the vicinity of the outlet pipe was damaged with some damage to the roof section close to the pipe.

Planned works: Further investigation works have been undertaken prior to any repair works being commenced on boiler 1. This included metallurgical testing to confirm initial conclusions and ensure the efficacy of the boiler to be repaired. Personnel communication with the author of the report has confirmed that the condition of pipework to be welded too as part of the repairs is more than adequate for these purposes. The header and all affected or damaged external pipework is to be replaced as a precaution. The completed works will include the testing and recertification of the boiler by a competent pressure vessel company and confirmation that the works carried out are

acceptable to Scotgen's appointed competent person 'Allianz Engineering' under the written Scheme of Examination. The following works have been undertaken prior to works recommencing:

Stream 2

- Test temperature safety trip switch system and risk assess its suitability. The previously installed temperature trip switch has been replaced with a thermocouple type instrument that will allow a warning and alarm to be activated before any activation of the trip. Scotgen are replacing the 'latching type temperature switch' with a 'temperature sensor and controller'. The new installation has the advantage of being able to measure continuous temperature which will allow monitoring of normal running temperatures. The new set up will be installed on both streams.
- Amend/ review operating manual.
- Revisit operator training and revise documentation.
- Review boiler venting procedure.

Stream 1

- Undertake metallurgical laboratory analysis of damaged pipework.
- Competent contractor to undertake pipework repair, appointed.
- Replacement of the temperature switch.
- Hydro-test boiler to allow recertification of the boiler with the relevant Insurer's / Scotgen's competent person 'Allianz Engineering'.

End



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Lifting Valves Test Certificate

Greens Power Reference No: SVL3036

Site Name: Sutton Ltd, Denby

Date of Lift/Test: 5th March 2012

Description of Equipment Lifted:

SAFETY VALVES BOILER NO 1

SV 3168 / 1

SV 3169 / 1



SV 3224 / 1

46.5 Bar



47.7 Bar

44 Bar

We hereby certify that the above equipment has been lifted/tested in accordance with our Standard Operating Procedures and have recorded the lift/test as being satisfactory.

  6-3-12
SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a lift/test has been carried out on the above named equipment and the lift/test was recorded as being satisfactory.

 6/4/2012 
SIGNATURE (on behalf of Client) NAME (PRINT)

L. J. JONES

OVF157



GREENS

Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Greens Power Reference No: 1591 725 17
Site Name or Ship's Name: Broomfield
Date of Test: 24 November 2010
Hydraulic Test Pressure: 200 bar
Pressure Gauge No: 12746-100-1
Date of Last Calibration: 17/05/2010

Description of Equipment Tested:

1. 1000 Bar Hydraulic Test Equipment
2. 1000 Bar Hydraulic Test Equipment
3. 1000 Bar Hydraulic Test Equipment

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.

SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.

SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client) NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Greens Power Reference No: OVL3036A
Site Name or Ship's Name: Scotgen Limited, Dumfries
Date of Test: 14/9/2011
Hydraulic Test Pressure: 144.8 bar
Pressure Gauge No: 072558
Date of Last Calibration: 5/5/11

Description of Equipment Tested:

Economiser Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.

GPL
QC3

SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.

WITNESSED BY
14/09/11
John
Kempster

SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client)

NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Greens Power Reference No: OVL3036A
Site Name or Ship's Name: Scotgen Limited, Dumfries
Date of Test: 9/9/2011
Hydraulic Test Pressure: 147.1 bar
Pressure Gauge No: 5/5/2011
Date of Last Calibration: 072558.

Description of Equipment Tested:


Secondary Evaporator Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.

GPL
QC3

SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.



SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client)

NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Greens Power Reference No: OVL3036A
Site Name or Ship's Name: Scotgen Limited, Dumfries
Date of Test: 16/9/11
Hydraulic Test Pressure: 142.8 bar
Pressure Gauge No: 072 558
Date of Last Calibration: 5/5/11

Description of Equipment Tested:

Primary Superheater Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.



SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.



SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client)

NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Greens Power Reference No: OVL3036A
Site Name or Ship's Name: Scotgen Limited, Dumfries
Date of Test: 26/9/11
Hydraulic Test Pressure: 118 bar
Pressure Gauge No: 072558
Date of Last Calibration: 5/5/11

Description of Equipment Tested:

Primary Evaporator Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.



SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.

SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client)

NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above



EC CERTIFICATE OF CONFORMITY (MODULE G)
GREENS POWER LIMITED
PRESSURE VESSEL
CERTIFICATE NO: COV1112456/2 SCHEDULE

EQUIPMENT DATA

Type: Waste Heat Recovery Boilers (W2E)

Maximum Design Pressure: Economiser = 60.5 Barg; Evaporators = 50.6 Barg;
Superheaters = 47.3 Barg

Capacity: Economiser = 1118.80 kg; Primary Evaporator = 1702.31 kg;
Secondary Evaporator = 772.51 kg;
Primary Superheater = 1035.63 kg;
Secondary Superheater = 517.81 kg

The undermentioned documents have been reviewed for compliance with the Pressure Equipment Directive 97/23/EC and following Design Code(s):

BS EN12952: 2001

TECHNICAL FILE CONTENTS

As detailed in Design Appraisal Document COV1112456 O-23387/PKC


LRV REPORTS

Design Appraisal Document	COV1112456 O-23387/PKC	19 October 2011
Inspection Certificate	COV1112456/01	02 March 2012

Schedule Issue: 1

Date of Schedule Issue: 13 March 2012

LRV Notified Body Number 0038


on behalf of Lloyd's Register Verification



This certificate is issued to:

LRV Notified Body Number 0038

2. The following information is submitted in the event that any conflict with party arises. The following information is submitted in the event that any conflict with party arises. The following information is submitted in the event that any conflict with party arises.



Inspection Certificate

Project **Ascot Environmental Ltd.**
(Order 27746 Job No. 06/409)
2 off Waste Heat Boilers (W2E), Dargavel

Client **Greens Power Limited**
Raines House, Denby Dale Road,
Wakefield, WF1 1HR, England

Office **Coventry**

Client's Order Number **A8396; OVL3036A**

Date **02 March 2012**

Order Status **Complete**

Inspection Dates

First **31 May 2011**

Final **27 February 2012**

This certificate is issued to **GREENS POWER LIMITED.**, to certify that the undersigned did at their request attend their workshop in Calder Vale Road, Wakefield, for the purpose of examining the items listed below, manufactured to Works Order No. OVL3036A: -

Description: 2 off Waste Heat Boilers (W2E), each comprising:-
Primary Evaporator
Secondary Evaporator
Primary Superheater
Secondary Superheater
Economiser

Code: BS EN 12952: 2001 & the Pressure Equipment Directive 97/23/EC Module G
Drawings: OVL3036-01 Rev. B and sub-level drawings as per Design Appraisal Document

The following examinations were carried out in accordance with Code & ITP No. OVL3036A/ITP1 Issue D: -

1. Review of Design Appraisal Document: COV1112456 O-23387/PKC dated 19 October 2011 Issue 1 refers
2. Review of Weld Index Sheet
3. Review of Welding Procedures, Procedure Qualifications and Welder Qualifications
4. Identification of materials and review of certification
5. Monitor fabrication
6. Review of NDE results
7. Witness of unit hydrostatic pressure tests at 118 barg (Primary Evaporators); 147.1 barg (Secondary Evaporators), 142.8 barg (Primary/Secondary Superheaters); and 144.8 barg (Economisers)
8. Verify calibration status of test equipment used
9. Final Inspection
10. Review stamping of nameplates
11. Review of documentation

All of the above was carried out to the satisfaction of the undersigned. On the basis of the scope of inspection undertaken, the equipment has been found to comply with specification requirements

For identification purposes the nameplates were stamped: 'ILRs'



Lloyd's Register EMEA

A member of the Lloyd's Register Group

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Green's Power Reference No: OVL3036A

Site Name or Ship's Name: Scotgen Limited, Dumfries

Date of Test: 26/9/11

Hydraulic Test Pressure: 118 bar

Pressure Gauge No: 072558

Date of Last Calibration: 5/5/11

Description of Equipment Tested:

Primary Evaporator Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.



SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.

SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client)

NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Greens Power Reference No: OVL3036A
Site Name or Ship's Name: Scotgen Limited, Dumfries
Date of Test: 16/9/11
Hydraulic Test Pressure: 142.8 bar
Pressure Gauge No: 072 558
Date of Last Calibration: 5/5/11

Description of Equipment Tested:

Primary Superheater Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.



SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.



SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client)

NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above

ATEX/IECEX/CSA/FM

TAG NOS
TS3377/1
TS3377/2

ATEX/IECEX/CSA/FM

DECLARATION OF CONFORMITY

This is to confirm that the BETA explosion proof pressure & temperature switches comply to the below mentioned applicable certificates.
Special attention should be paid to the additional comments like "Installation Instruction" and "Special conditions for safe use" as they are regarded to be an integral part of this Installation Manual.

V.- enclosure	KEMA 02ATEX2186	Ex II 2 G Ex d IIC T6 or II 2 G Ex d IIC T5 Ex II 2 D Ex tD A21 IP65 T100°C													
<table border="1"> <tr> <td>MODEL</td> <td>BETA B SWITCH</td> <td>CE-0344</td> <td rowspan="4"> II 2 G Ex d IIC T6 -40°C + Tamb + 70°C II 2 G Ex d IIC T5 -40°C + Tamb + 80°C II 2 D Ex tD A21 IP65 T100°C -40°C + Tamb + 80°C U max.-V I max.-A KEMA 02ATEX2186 IP 65 www.beta-b.nl </td> </tr> <tr> <td>RANGE</td> <td>SERIAL No:</td> <td>AC</td> </tr> <tr> <td>OVERRANGE PROOF</td> <td>TAG No:</td> <td>DC</td> </tr> <tr> <td colspan="3">MADE BY BETA BV - VERRIJN STUARTLAAN 22 - 2288 EL RIJSWIJK - THE NETHERLANDS</td> </tr> </table>			MODEL	BETA B SWITCH	CE-0344	II 2 G Ex d IIC T6 -40°C + Tamb + 70°C II 2 G Ex d IIC T5 -40°C + Tamb + 80°C II 2 D Ex tD A21 IP65 T100°C -40°C + Tamb + 80°C U max.-V I max.-A KEMA 02ATEX2186 IP 65 www.beta-b.nl	RANGE	SERIAL No:	AC	OVERRANGE PROOF	TAG No:	DC	MADE BY BETA BV - VERRIJN STUARTLAAN 22 - 2288 EL RIJSWIJK - THE NETHERLANDS		
MODEL	BETA B SWITCH	CE-0344	II 2 G Ex d IIC T6 -40°C + Tamb + 70°C II 2 G Ex d IIC T5 -40°C + Tamb + 80°C II 2 D Ex tD A21 IP65 T100°C -40°C + Tamb + 80°C U max.-V I max.-A KEMA 02ATEX2186 IP 65 www.beta-b.nl												
RANGE	SERIAL No:	AC													
OVERRANGE PROOF	TAG No:	DC													
MADE BY BETA BV - VERRIJN STUARTLAAN 22 - 2288 EL RIJSWIJK - THE NETHERLANDS															
W.-enclosure	ITS09ATEX16437	Ex II 2 G Ex d IIC T6 or II 2 G Ex d IIC T5 Ex II 2 D Ex tD A21 IP6X T100°C													
W.-enclosure	IECEX KEM 07.0034	Ex d IIC T6 or Ex d IIC T5 Ex tD A21 T100°C IP66													
W.-enclosure	CSA No.:1873316	Class I/II/III, Div. 1, Groups B/C/D/E/F/G Zone 1 Ex d IIC T6 DIP A21 TA 100°C													
W.-enclosure	FM No.: 3028962	Class I/II/III, Div. 1, Groups A/B/C/D/E/F/G Zone 1 AEx d IIC T6													
<table border="1"> <tr> <td>MODEL</td> <td>BETA B SWITCH</td> <td>CE-0344</td> <td rowspan="4"> II 2 G Ex d IIC T6 -40°C + Tamb + 70°C II 2 G Ex d IIC T5 -40°C + Tamb + 80°C II 2 D Ex tD A21 IP66 T100°C -40°C + Tamb + 80°C U max.-V I max.-A ITS09ATEX16437 Low Temp for ATEX: -60°C IECEX KEM 07.0034 IP 66 / NEMA 4X CSA 07.1873316 FM No.: 3028962 www.beta-b.nl </td> </tr> <tr> <td>RANGE</td> <td>SERIAL No:</td> <td>AC</td> </tr> <tr> <td>OVERRANGE PROOF</td> <td>TAG No:</td> <td>DC</td> </tr> <tr> <td colspan="3"> CSA: Class I/II/III, Div. 1, Groups B,C,D,E,F,G; Class 1, Zone 1 Ex d IIC T6 -40°C + Tamb + 70°C or T5 -40°C + Tamb + 80°C DIP A21 TA 100°C FM: Class I/II/III, Div. 1, Groups A,B,C,D,E,F,G; Class 1, Zone 1 AEx d IIC T6 -40°C + Tamb + 70°C or T5 -40°C + Tamb + 80°C MADE BY BETA BV - VERRIJN STUARTLAAN 22 - 2288 EL RIJSWIJK - THE NETHERLANDS </td> </tr> </table>			MODEL	BETA B SWITCH	CE-0344	II 2 G Ex d IIC T6 -40°C + Tamb + 70°C II 2 G Ex d IIC T5 -40°C + Tamb + 80°C II 2 D Ex tD A21 IP66 T100°C -40°C + Tamb + 80°C U max.-V I max.-A ITS09ATEX16437 Low Temp for ATEX: -60°C IECEX KEM 07.0034 IP 66 / NEMA 4X CSA 07.1873316 FM No.: 3028962 www.beta-b.nl	RANGE	SERIAL No:	AC	OVERRANGE PROOF	TAG No:	DC	CSA: Class I/II/III, Div. 1, Groups B,C,D,E,F,G; Class 1, Zone 1 Ex d IIC T6 -40°C + Tamb + 70°C or T5 -40°C + Tamb + 80°C DIP A21 TA 100°C FM: Class I/II/III, Div. 1, Groups A,B,C,D,E,F,G; Class 1, Zone 1 AEx d IIC T6 -40°C + Tamb + 70°C or T5 -40°C + Tamb + 80°C MADE BY BETA BV - VERRIJN STUARTLAAN 22 - 2288 EL RIJSWIJK - THE NETHERLANDS		
MODEL	BETA B SWITCH	CE-0344	II 2 G Ex d IIC T6 -40°C + Tamb + 70°C II 2 G Ex d IIC T5 -40°C + Tamb + 80°C II 2 D Ex tD A21 IP66 T100°C -40°C + Tamb + 80°C U max.-V I max.-A ITS09ATEX16437 Low Temp for ATEX: -60°C IECEX KEM 07.0034 IP 66 / NEMA 4X CSA 07.1873316 FM No.: 3028962 www.beta-b.nl												
RANGE	SERIAL No:	AC													
OVERRANGE PROOF	TAG No:	DC													
CSA: Class I/II/III, Div. 1, Groups B,C,D,E,F,G; Class 1, Zone 1 Ex d IIC T6 -40°C + Tamb + 70°C or T5 -40°C + Tamb + 80°C DIP A21 TA 100°C FM: Class I/II/III, Div. 1, Groups A,B,C,D,E,F,G; Class 1, Zone 1 AEx d IIC T6 -40°C + Tamb + 70°C or T5 -40°C + Tamb + 80°C MADE BY BETA BV - VERRIJN STUARTLAAN 22 - 2288 EL RIJSWIJK - THE NETHERLANDS															
Installation instruction : The cable glands and blanking elements shall be in type of explosion protection flameproof enclosure "d" suitable for the conditions of use and correctly installed. The devices shall provide a degree of protection of IP6X. For temperatures under rated conditions higher than 70 °C at the cable point, suitable heat resistant cables and cable glands shall be used. The installation cable has to be suitable for a temperature of ≥ 130 °C. Special conditions for safe use : The relation between the ambient temperature range and temperature class is listed at sub (15) of the original certificate : Ambient temperature range ATEX -60°C to +70°C for T6 -60°C to +80°C for T5/100°C Ambient temperature range IECEX/CSA/FM: -40°C to +70°C for T6 -40°C to +80°C for T5 Max. electrical rating: 480VAC/ 10A(depending on selected micro switch) Max. pressure range: 54 MPa / 540 Bar / 7838 Psi The enclosure fulfills the requirements of: ATEX: EN 60079-0:2006/ EN 60079-1:2007/ EN 61241-0:2006/ EN 61241-1:2004 IEC: IEC 60079-0:2004/ IEC 60079-1:2003/ IEC 61241-0:2004/ IEC 61241-1:2004 CSA: C22.2 No. 0-M91/ C22.2 No. 61010-1-04/ C22.2 No. 30-M1986 FM: FM Approval Standard Class No. 3810/ No. 3615 ANSI/ISA S82.01-1994/ S82.03-1988 NEMA 250 -2003 (4X)															



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515




Hydraulic Pressure Test Certificate

Greens Power Reference No: OVL3036A
Site Name or Ship's Name: Scotgen Limited, Dumfries
Date of Test: 10/4/11
Hydraulic Test Pressure: 142.8 bar
Pressure Gauge No: 072558
Date of Last Calibration: 5/5/11



Description of Equipment Tested:



Secondary Superheater Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.

  
SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.

 
SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

 
SIGNATURE (on behalf of Client) NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above



Raines House
Denby Dale Road
Wakefield
WF1 1HR
England

Telephone: +44 (0)1924 203970
General Fax: +44 (0)1924 387320
Spares/Service Fax: +44(0)1924 377515

Hydraulic Pressure Test Certificate

Greens Power Reference No: OVL3036A
Site Name or Ship's Name: Scotgen Limited, Dumfries
Date of Test: 9/9/2011
Hydraulic Test Pressure: 147.1 bar
Pressure Gauge No: 5/5/2011
Date of Last Calibration: 072558.

Description of Equipment Tested:


Secondary Evaporator Boiler 1

We hereby certify that the above equipment has been tested in accordance with our Standard Operating Procedures and have recorded the test as being satisfactory.

GPL
QC3

SIGNATURE (on behalf of Greens Power Limited) NAME (PRINT)

We, the undersigned, certify as witnesses that a hydraulic test has been carried out on the above named equipment and the test was recorded as being satisfactory.



SIGNATURE (on behalf of Inspecting Authority) NAME (PRINT)

SIGNATURE (on behalf of Client)

NAME (PRINT)

OVF083/1

GREENS POWER LIMITED
Registered in England No. 5067893
Registered office as above